

2005 Consumer Confidence Report

WESTCHESTER LAKES SUBDIVISION, PWS ID 24607946

Water System Information

If you would like to know more about the information contained in this report, please contact Layne Nw - Dave Kowalczyk at (262) 246-4646.

Health Information

Drinking water, including bottled water, may reasonably be expected to contain at least small amounts of some contaminants. The presence of contaminants does not necessarily indicate that water poses a health risk. More information about contaminants and potential health effects can be obtained by calling the Environmental Protection Agency's safe drinking water hotline (800-426-4791).

Some people may be more vulnerable to contaminants in drinking water than the general population. Immuno-compromised persons such as persons with cancer undergoing chemotherapy, persons who have undergone organ transplants, people with HIV/AIDS or other immune systems disorders, some elderly, and infants can be particularly at risk from infections. These people should seek advice about drinking water from their health care providers. EPA/CDC guidelines on appropriate means to lessen the risk of infection by cryptosporidium and other microbial contaminants are available from the Environmental Protection Agency's safe drinking water hotline (800-426-4791).

Source(s) of Water

Source ID	Unique Well #	Source	Depth (ft.)	Name	Location
1	DC802	Groundwater	410	7105 LaFayette	LAFAYETTE DR LOTS 27 & 28
2	CW452	Groundwater	575	7314 LaFayette	LOT 81/80 LAFAYETTE DR

A summary of the source water assessment for WESTCHESTER LAKES SUBDIVISION is available at:

http://prodoasext.dnr.wi.gov/inter1/pk_swap_web.p_swap_summary?i_ro_seq_no=138015

Educational Information

The sources of drinking water, both tap water and bottled water, include rivers, lakes, streams, ponds, reservoirs, springs and wells. As water travels over the surface of the land or through the ground, it dissolves naturally occurring minerals and, in some cases, radioactive material, and can pick up substances resulting from the presence of animals or from human activity.

Contaminants that may be present in source water include:

1. Microbial contaminants, such as viruses and bacteria, which may come from sewage treatment plants, septic systems, agricultural livestock operations and wildlife.
2. Inorganic contaminants, such as salts and metals, which can be naturally- occurring or result from urban stormwater runoff, industrial or domestic wastewater discharges, oil and gas production, mining or farming.
3. Pesticides and herbicides, which may come from a variety of sources such as agriculture, urban stormwater runoff and residential uses.
4. Organic chemical contaminants, including synthetic and volatile organic chemicals, which are by-products of industrial processes and petroleum production, and can also come from gas stations, urban stormwater runoff and septic systems.

In order to ensure that tap water is safe to drink, EPA prescribes regulations that limit the amount of certain contaminants in water provided by public water systems. FDA regulations establish limits for contaminants in bottled water, which sha

Number of Contaminants Required to be Tested

This table displays the number of contaminants that were required to be tested in the last five years. The CCR may contain up to five years worth of water quality results. If a water system tests annually, or more frequently, the results from the most recent year are shown on the CCR. If testing is done less frequently, the results shown on the CCR are from the past five

Contaminant Group	# of Contaminant
Inorganic Contaminants	4
Radioactive Contaminants	1
Microbiological Contaminants	2
Synthetic Organic Contaminants including Pesticides and Herbicides	24

Inorganic Contaminants

Contaminant	MCL	MCLG	Level Found	Range	Sample Date (if Prior to 2005)	Violation	Typical Source of Contaminant
COPPER (ppm)	AL=1.3	1.3	.8205	.1320-.9120	01/24/2004	NO	Corrosion of household plumbing systems; Erosion of natural deposits; Leaching from wood preservatives
LEAD (ppb)	AL=15	0	2.02	.00-2.12	01/21/2004	NO	Corrosion of household plumbing systems; Erosion of natural deposits
NITRATE (NO3-N) (ppm)	10	10	.02 (average)	nd-.03		NO	Runoff from fertilizer use; Leaching from septic tanks, sewage; Erosion of natural deposits
SODIUM (ppm)	n/a	n/a	31.40	18.50-31.40	09/29/2003	NO	n/a

Radioactive Contaminants

Contaminant	MCL	MCLG	Level Found	Range	Sample Date (if Prior to 2005)	Violation	Typical Source of Contaminant
GROSS ALPHA, EXCL. R & U (pCi/l)	15	0	.7	.7-.7	09/29/2003	NO	Erosion of natural deposits